

June 8, 2016

Jessie Byrd,

Effective immediately, the PEARL RIVER VALLEY WATER SUPPLY DISTRICT has issued a Boil Water Notice for the Breakers Subdivision on the Main Harbor water system PWS# 450019. This notice was issued due to loss of water or water pressure. The loss of water or water pressure was due to a broken 6 inch main.

There are 86 water connections affected in the subdivision. The Mississippi State Department of Health was notified by telephone and this email.

We will take the first of the two samples from the affected area on June 8, 2016. This boil water notice will be in effect for at least 48 hours or until we receive two consecutive days of clear sampling.

Thank You,

Steve Clark
Division Director II
Reservoir Maintenance Facility
Pearl River Valley Water Supply District