

February 11, 2016

Jessie Byrd,

Effective immediately, the PEARL RIVER VALLEY WATER SUPPLY DISTRICT has issued a Boil Water Notice for street Red Oak Trail in Bay Pointe subdivision on the Pelahatchie Bay water system PWS# 610036. This notice was issued due to loss of water or water pressure. The loss of water or water pressure was due to a broken 8 inch main.

There are 80 water connections affected in the subdivision. The Mississippi State Department of Health was notified by telephone and this email.

We will take the first of the two samples from the affected area on February 11, 2016. This boil water notice will be in effect for at least 48 hours or until we receive two consecutive days of clear sampling.

Door hangers have been posted to alert the water customers to vigorously boil for one minute any water to be consumed.

Thank You,

Steve Clark  
Division Director II  
Reservoir Maintenance Facility  
Pearl River Valley Water Supply District